

**Table 1. Level 4 Requirements Deletions Table. This table identifies deletions to existing “Derived” L4 requirements that are facility related in the RTM database version 091696.**

| L4 id       | req_key | rel | req_type | req_status  | verification_method | text   |
|-------------|---------|-----|----------|-------------|---------------------|--|
| S-IOS-60010 | -10970  | A   | derived  | incremental | demo                | The electrical power requirements for ADSHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                    |
| S-IOS-60020 | -10971  | A   | derived  | incremental | demo                | The air conditioning requirements for the ADSHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                |
| S-IOS-60030 | -10972  | A   | derived  | incremental | demo                | The grounding requirements for ADSHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                               |
| S-IOS-60040 | -10973  | A   | derived  | incremental | demo                | The fire alarm requirements for ADSHW CI equipment shall be in accordance with )ECS Facilities Plan (DID 302/DV2).                             |
| S-IOS-60050 | -10974  | A   | derived  | incremental | demo                | The acoustical requirements for ADSHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-IOS-60060 | -10975  | A   | derived  | incremental | demo                | The physical interface requirements between ADSHW CI equipment and the facility shall be in accordance with ECS Facilities Plan (DID 302/DV2). |
| S-IOS-60070 | -10976  | A   | derived  | incremental | demo                | The footprint size and the physical layout of ADSHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).            |
| S-DMS-60010 | -10977  | A   | derived  | incremental | demo                | The electrical power requirements for DMGHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                    |
| S-DMS-60020 | -10978  | A   | derived  | incremental | demo                | The air conditioning requirements for the DMGHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                |
| S-DMS-60030 | -10979  | A   | derived  | incremental | demo                | The grounding requirements for DMGHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                               |
| S-DMS-60040 | -10980  | A   | derived  | incremental | demo                | The fire alarm requirements for DMGHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DMS-60050 | -11169  | A   | derived  | incremental | demo                | The acoustical requirements for DMGHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DMS-60060 | -10981  | A   | derived  | incremental | demo                | The physical interface requirements between DMGHW CI equipment and the facility shall be in accordance with ECS Facilities Plan (DID 302/DV2). |
| S-DMS-60070 | -10982  | A   | derived  | incremental | demo                | The footprint size and the physical layout of DMGHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).            |
| S-DSS-60010 | -10983  | A   | derived  | approved    | demo                | The electrical power requirements for ACMHW CI equipment shall be in   |

| L4id        | req_key | rel | req_type | req_status | verification_method | text   |
|-------------|---------|-----|----------|------------|---------------------|--|
|             |         |     |          |            |                     | accordance with the ECS Facilities Plan (DID 302/DV2).   |
| S-DSS-60020 | -10984  | A   | derived  | approved   | demo                | The air conditioning requirements for the ACMHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                |
| S-DSS-60030 | -10985  | A   | derived  | approved   | demo                | The grounding requirements for ACMHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                               |
| S-DSS-60040 | -10986  | A   | derived  | approved   | demo                | The fire alarm requirements for ACMHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DSS-60050 | -10987  | A   | derived  | approved   | demo                | The acoustical requirements for ACMHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DSS-60060 | -10988  | A   | derived  | approved   | demo                | The physical interface requirements between ACMHW CI equipment and the facility shall be in accordance with ECS Facilities Plan (DID 302/DV2). |
| S-DSS-60070 | -10989  | A   | derived  | approved   | demo                | The footprint size and the physical layout of ACMHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).            |
| S-DSS-70010 | -10990  | A   | derived  | approved   | demo                | The electrical power requirements for WKSHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                    |
| S-DSS-70020 | -10991  | A   | derived  | approved   | demo                | The air conditioning requirements for the WKSHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                |
| S-DSS-70030 | -10992  | A   | derived  | approved   | demo                | The grounding requirements for WKSHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                               |
| S-DSS-70040 | -10993  | A   | derived  | approved   | demo                | The fire alarm requirements for WKSHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DSS-70050 | -10994  | A   | derived  | approved   | demo                | The acoustical requirements for WKSHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DSS-70060 | -10995  | A   | derived  | approved   | demo                | The physical interface requirements between WKSHW CI equipment and the facility shall be in accordance with ECS Facilities Plan (DID 302/DV2). |
| S-DSS-70070 | -10996  | A   | derived  | approved   | demo                | The footprint size and the physical layout of WKSHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).            |
| S-DSS-80010 | -10997  | A   | derived  | approved   | demo                | The electrical power requirements for DRPHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                    |
| S-DSS-80020 | -10998  | A   | derived  | approved   | demo                | The air conditioning requirements for the DRPHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                |
| S-DSS-80030 | -10999  | A   | derived  | approved   | demo                | The grounding requirements for DRPHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                               |

| L4 id       | req_key | rel | req_type | req_status | verification_method | text   |
|-------------|---------|-----|----------|------------|---------------------|--|
| S-DSS-80040 | -11000  | A   | derived  | approved   | demo                | The fire alarm requirements for DRPHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DSS-80050 | -11001  | A   | derived  | approved   | demo                | The acoustical requirements for DRPHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DSS-80060 | -11002  | A   | derived  | approved   | demo                | The physical interface requirements between DRPHW CI equipment and the facility shall be in accordance with ECS Facilities Plan (DID 302/DV2). |
| S-DSS-80070 | -11003  | A   | derived  | approved   | demo                | The footprint size and the physical layout of DRPHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).            |
| S-DSS-90010 | -11004  | A   | derived  | approved   | demo                | The electrical power requirements for DIPHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                    |
| S-DSS-90020 | -11005  | A   | derived  | approved   | demo                | The air conditioning requirements for the DIPHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                |
| S-DSS-90030 | -11006  | A   | derived  | approved   | demo                | The grounding requirements for DIPHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                               |
| S-DSS-90040 | -11007  | A   | derived  | approved   | demo                | The fire alarm requirements for DIPHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DSS-90050 | -11008  | A   | derived  | approved   | demo                | The acoustical requirements for DIPHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DSS-90060 | -11009  | A   | derived  | approved   | demo                | The physical interface requirements between DIPHW CI equipment and the facility shall be in accordance with ECS Facilities Plan (DID 302/DV2). |
| S-DSS-90070 | -11010  | A   | derived  | approved   | demo                | The footprint size and the physical layout of DIPHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).            |
| S-INS-60570 | -11013  | A   | derived  | approved   | demo                | The acoustical requirements for ICLHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DPS-60770 | -11017  | A   | derived  | approved   | demo                | The acoustical requirements for SPRHW CI equipment shall be in accordance with ECS Facilities Plan (DID 302/DV2).                              |
| S-DPS-70770 | -11018  | A   | derived  | approved   | test/demo           | The acoustical requirements for AITHW CI equipment shall be in accordance with the ECS Facilities Plan (DID 302/DV2).                          |